

排水 (平成二十六年十二月分)	測定日	1	2	3	4	5	6	7	8	9	10		
	測定項目												
	COD (kg/day)	0.50	0.46	0.47	0.59	0.54	0.55	0.47	0.52	0.25	0.12		
	全窒素 (kg/day)	0.49	0.31	0.24	0.37	0.35	0.36	0.35	0.45	0.27	0.04		
	全燐 (kg/day)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		
	測定日	11	12	13	14	15	16	17	18	19	20		
	測定項目												
	COD (kg/day)	0.17	0.20	0.22	0.20	0.23	0.24	0.24	0.23	0.25	0.28		
	全窒素 (kg/day)	0.05	0.04	0.04	0.03	0.03	0.03	0.04	0.03	0.04	0.04		
	全燐 (kg/day)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		
	測定日	21	22	23	24	25	26	27	28	29	30		31
	測定項目												
COD (kg/day)	0.24	0.31	0.25	0.26	0.33	0.24	0.07	0.07	0.08	0.08	0.09		
全窒素 (kg/day)	0.03	0.04	0.04	0.04	0.05	0.06	0.04	0.03	0.05	0.04	0.05		
全燐 (kg/day)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		
備考	数値は全自動汚濁負荷装置の1日当たりの累積値(kg/day) 排水水における許容汚濁負荷量の計算式 (特定施設別係数) × (排水処理設備認可能力) = (許容汚濁負荷量) COD : 20mg/ℓ × 1,514m ³ /day = 30.28kg/day 全窒素 : 10mg/ℓ × 1,514m ³ /day = 15.14kg/day 全燐 : 1mg/ℓ × 1,514m ³ /day = 1.514kg/day												