

|  |   |      |      |      |      |      |      |      |      |      |      |
|--|---|------|------|------|------|------|------|------|------|------|------|
| 排水<br>水<br>(<br>令<br>和<br>三<br>年<br>五<br>月<br>分) | 測定日   | 1    | 2    | 3    | 4    | 5    | 6    | 7    | 8    | 9    | 10   |
|  | 測定項目  |      |      |      |      |      |      |      |      |      |      |
|  | COD (kg/day)  | 0.08 | 0.00 | 0.00 | 0.00 | 0.00 | 0.02 | 0.00 | 0.00 | 0.00 | 0.00 |
|  | 全窒素 (kg/day)  | 0.01 | 0.00 | 0.00 | 0.00 | 0.07 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
|  | 全燐 (kg/day)   | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
|  | 測定日   | 11   | 12   | 13   | 14   | 15   | 16   | 17   | 18   | 19   | 20   |
|  | 測定項目  |      |      |      |      |      |      |      |      |      |      |
| COD (kg/day)                                     | 0.15  | 0.24 | 0.05 | 0.23 | -    | -    | -    | -    | -    | -    |      |
| 全窒素 (kg/day)                                     | 0.02  | 0.03 | 0.00 | 0.01 | -    | -    | -    | -    | -    | -    |      |
| 全燐 (kg/day)                                      | 0.00  | 0.00 | 0.00 | 0.00 | -    | -    | -    | -    | -    | -    |      |
| 備考   | 数値は全自動汚濁負荷装置の1日当たりの累積値(kg/day)<br>排水水における許容汚濁負荷量の計算式<br>(特定施設別係数) × (排水処理設備認可能力) = (許容汚濁負荷量)<br>COD : 20mg/ℓ × 1,514m <sup>3</sup> /day = 30.28kg/day<br>全窒素 : 10mg/ℓ × 1,514m <sup>3</sup> /day = 15.14kg/day<br>全燐 : 1mg/ℓ × 1,514m <sup>3</sup> /day = 1.514kg/day |      |      |      |      |      |      |      |      |      |      |